

**Village of Hanover Park  
2121 Lake St.  
Hanover Park, IL 60133**

Separate sealed Bids are solicited for the following project:

**Project Name: 1,000,000 Gallon Reservoir (Well No. 4 South Tank)  
Exterior Overcoat  
Wet Interior Repaint  
and Miscellaneous Repairs**

Note: This project name shall be understood to include the entire scope of project as defined and detailed by these specifications.

Scope of Work:

Exterior: High pressure water clean (5,000-10,000 psi), spot power tool clean to a SSPC-SP11 standard, and apply a three (3) coat epoxy urethane system.

Wet Interior: Abrasive blast clean to a SSPC-SP10 near white metal standard, and apply a three (3) coat zinc epoxy system. The cathodic protection system is to be removed during work and reinstalled (with replacement reference cells and parts) by the owner's vendor (Corrpro) after topcoat is cured. Coordination and cost is contractor's responsibility.

Pit Piping: Abrasive blast clean to a SSPC-SP6 commercial standard, and apply a two (2) coat epoxy system.

Foundation: Water clean, apply resurfacer, and a two (2) coat epoxy system.

Repairs:

- 1) Install sidewall manway.
- 2) Replace manway gasket.
- 3) Install overflow flap gate.
- 4) Install new step-off platform and roof railing.
- 5) Replace vent with a frost-free roof vent.
- 6) Install roof couplings with safety clips.
- 7) Install latch on ladder vandal guard.

Separate sealed bids will be received by the Owner and then publicly opened and read aloud at:

Bid Opening Site: **Village of Hanover Park, Office of the Village Clerk, 2121 Lake St.,  
Hanover Park, IL 60133**

Bid Opening Date: **January 15, 2013**

Bid Opening Time: **11:00 A.M. (local time)**

The SPECIFICATIONS/PLANS may be examined at the following locations:

Construction Association  
43636 Woodward Ave.  
Bloomfield Hills, MI 48302

Contractors Exchange  
233 N. Springfield Ave.  
Joliet, IL 60435

Bid Tool  
One Oakbrook Terrace, Suite 510  
Oak Brook Terrace, IL 60181

iSq.Ft. Planroom  
c/o Cushing Co.  
420 W. Huron St.  
Chicago, IL 60654

At the OFFICE of the ENGINEER and at the OFFICE of Bob Wenger, Water Superintendent.

Copies of the SPECIFICATIONS/PLANS and PROPOSAL FORMS may be obtained at the office of DIXON ENGINEERING, INC., 1104 Third Avenue, Lake Odessa, Michigan, 48849 upon payment of **\$60.00** (handling charge for each set). Payment for SPECIFICATIONS should be made to Dixon Engineering, Incorporated. **There will be no refund of handling charge for return of specification packages.** Each BIDDER must deposit with his BID, Security in the amount, form, and subject to the conditions provided in the INFORMATION FOR BIDDERS. The OWNER reserves the right to accept any PROPOSAL, to reject any or all PROPOSALS, and to waive any irregularities in any PROPOSAL. No BIDDER may withdraw his BID within sixty (60) days after the actual date of the opening thereof.

Note 1: The Engineer assumes no responsibility to supply Builders Exchanges and similar plan review rooms with all addenda issued. An attempt will be made to do so; however, only registered plan holders will be notified by fax of expected addendum with short preparation times.

Note 2: Prequalification of BIDDERS - Dixon Engineering will review qualifications of all Contractors and determine their status. Contractors will be prequalified for different sized tanks and towers based on experience, workmanship, and financial data. Any Contractor who has any projects in dispute or unfinished because of Contract problems will be considered NOT prequalified. CONTRACTORS wishing to be prequalified must submit their latest financial statement and a list of ten (10) similar sized projects using similar coating systems. Failure to submit may result in rejection of bid. A prequalification status may be upgraded or downgraded during the course of the season as a result of new data submitted, resolution or origination of project conflicts.

BIDDERS who are not prequalified shall submit the following notarized form with their bid:

BIDDER's Sworn Work History Statement:

Not less than the prevailing rate of wages as found by the Village of Hanover Park, or the Department of Labor, or determined by the court on review shall be paid to all laborers, workmen, and mechanics performing work under this contract.